


WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 47743 / 47744
 Permit No. _____
 Basin. 061



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25579

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 29 BARRICK GOLDSTRIKE MINE
ELKO, NEVADA 89801

2. LOCATION SE 1/4 SE 1/4 Sec. 5 T. 36 NS R. 49 E. EUREKA County
 PERMIT NO. M/O-795 N/A N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY, RED & BLACK ROCK		0	100	100
GRAY, RED & BLACK ROCK WITH TAN CLAY	2GPM	100	600	500
GREEN, GRAY ROCK SOME CLAY		600	650	50
BLACK BED ROCK		650	850	200
FRACTURED GRAY ROCK	10 GPM	850	1,000	150
GRAY, RED & BROWN ROCK	10 GPM	1,000	1,350	350
GRAY & BROWN ROCK	15 GPM	1,350	1,980	630
GRAY, BROWN ROCK SOME CLAY	15 GPM	1,980	2,040	60
GRAY, BLACK & BROWN ROCK	15 GPM	2,040	2,140	100
GREEN & GRAY ROCK	15 GPM	2,140	2,170	30
BROWN & BLACK ROCK	15 GPM	2,170	2,200	30
BROWN, BLACK ROCK, SOME GREEN CLAY		2,200	2,300	100

8. WELL CONSTRUCTION
 Depth Drilled 2,300 Feet Depth Cased 2,300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
12 1/2	0	35
6 1/2	35	2,300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22	.250	0	35
1 1/2	3	SCHED. 80	0	420
2	5	.218	0	2,200

Perforations: Type perforation DRILL HOLES
 Size perforation 1/8"

From	To
1 1/2" / 420 feet	480 feet
2 / 2,200 feet	2,300 feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 400' / 2,170 feet to 480' / 2,300 feet

9. WATER LEVEL
 Static water level 340' & 927' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

Date started NOVEMBER 11, 1994
 Date completed NOVEMBER 17, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716

Signed DAVID HAAS
 Date _____