WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47751
Permit No.
Basin 212

NOTICE OF INTENT NO. 14423

1. OWNER CALNEV PIPELINE
MAILING ADDRESS P.O. BOX 6346
SAN BERNARDINO, CA 92408

ADDRESS AT WELL LOCATION VALLEY VIEW & HACIENDA INTERSECTION.

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 21 N(S)R. 61 E. CLARK County
PERMIT NO. MO-2400B (Issued by Water Resources) | N/A COPW ROW (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE RW-23
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT/FILL | | 0 | 1 | 1 |
| SILTY SAND | | 1 | 6 | 5 |
| CALICHE | | 6 | 11 | 5 |
| SILTY SAND | | 11 | 16 | 5 |
| CLAYEY GRAVEL | | 16 | 19 | 3 |
| SILTY SAND | | 19 | 22 | 3 |
| SAND | | 22 | 26 | 3 |
| SANDY CLAY | | 26 | 32 | 6 |
| SILTY SAND | | 32 | 35 | 3 |
| CALICHE | | 35 | 39 | 4 |
| CLAYEY SAND | | 39 | 45 | 6 |
| CALICHE | | 45 | 50 | 5 |
| SANDY GRAVEL | | 50 | 55 | 5 |
| SANDY CLAY | | 55 | 85 | 30 |

DCNR/DWR Received JUN 22 1995 LAS VEGAS OFFICE

Date started MAY 2, 1995
Date completed MAY 2, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 85 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | ~~[illegible]~~ 1.9 | 0.237 | 0 | 85 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 50 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-40'/40-46' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 46 feet to 85 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date 6-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627