BW-14

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47752
Permit No.
Basin 061

NOTICE OF INTENT NO. 71687

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SE ¼ Sec. 24 T 36 N/S R 49 E EUREKA County
PERMIT NO. 55139 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILICIFIED LIMESTONES/				
AND SILT STONES		0	1650	1650
HARD BLACK ROCK		1650	1845	195
FRACTURED BLACK ROCK		1845	1875	30
HARD BLACK ROCK		1875	1945	70
FRACTURED BLACK ROCK		1945	1963	18
HARD BLACK ROCK		1963	1971	8
FRACTURED BLACK ROCK		1971	1999	28
HARD BLACK ROCK		1999	2025	26
GRAY ROCK		2025	2076	51
FRACTURED BLACK ROCK		2076	2126	50
FRACTURED BLACK/				
GRAY ROCK		2126	2176	50

'94 NOV -2 AM 11:51
STATE ENGINEER

Date started 08-29-, 1994
Date completed 09-11-, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2176 Feet Depth Cased 2176 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
42	0	50
28	20	1650
19	1650	2176

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
34	135	.375	0	50
20	65.18	.312	+1	820

Perforations:
Type perforation ROSCOE MOSS LOUVERED
Size perforation .125
From 20" 820 feet to 1628 feet
From 16" 1628 feet to 2176 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 78
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 78 feet to 1628 feet

9. WATER LEVEL
Static water level 14.73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed Victor Hernandez (By driller performing actual drilling on site or contractor)
Date OCTOBER 26, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627