

OFFICE USE ONLY  
 Log No. 47755  
 Permit No. \_\_\_\_\_  
 Basin 061

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2214

1. OWNER Barrick Gold Strike Mine ADDRESS AT WELL LOCATION EW-17  
 MAILING ADDRESS P.O. Box 79  
Elko NV 89801  
 2. LOCATION NW 1/4 SE 1/4 Sec. 19 T. 36 N. R. 30 E. Eureka County  
 PERMIT NO. 55140 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, Gravel		0	40	40
Clay		40	170	130
Sand, Gravel		170	289	119
Hard Rock w/ Clay		289	1133	844
Black Rock		1133	1210	76

8. WELL CONSTRUCTION  
 Depth Drilled 1210 Feet Depth Cascd 1200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 36 Inches 0 Feet 45 Feet  
 To 17 1/2 Inches 45 Feet 1210 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24</u>	<u>94.62</u>	<u>3/8"</u>	<u>0</u>	<u>40</u>
<u>12</u>	<u>33.38</u>	<u>1/4"</u>	<u>0</u>	<u>1200</u>

Perforations:  
 Type perforation Roscoe Moss Full Flow Lower  
 Size perforation 1/8"  
 From 196 feet to 236 feet  
 From 276 feet to 1200 feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 103 feet to 1210 feet

Date started 3/13/94 19\_\_\_\_  
 Date completed 4/14/94 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Not Tested</u>			

9. WATER LEVEL  
 Static water level Not Available feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 90 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Layne-Western Contractor  
 Address 12030 E. Riggs Rd  
Chandler AZ 85249  
 Nevada contractor's license number issued by the State Contractor's Board 0019101  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1616  
 Signed Scott Campbell  
 By driller performing actual drilling on site or contractor  
 Date 11/14/94