WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47759
Permit No.
Basin 218

NOTICE OF INTENT NO. 14423

1. OWNER CALNEV PIPELINE
MAILING ADDRESS P.O. BOX 6346
SAN BERNARDINO, CA 92408

ADDRESS AT WELL LOCATION VALLEY VIEW AND HACIENDA INTERSECTION

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2400B (Issued by Water Resources) | N/A (Parcel No.) | CCPW ROW (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-25
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	1	1
GUSIFEROUS CLAY		1	5	4
CALICHE		5	13.5	8.5
SANDY CLAY		13.5	14.5	1
CALICHE		14.5	16.5	2
SILTY SAND		16.5	19.5	3
SANDY CLAY		19.5	24	4.5
SILTY SAND		24	38	14
CALICHE		38	39.5	1.5
SANDY CLAY		39.5	47.5	8
CALICHE		47.5	49.5	2
SILTY SAND		49.5	54	4.5
SANDY CLAY		54	65	11
CLAYEY GRAVEL		65	71	6
CALICHE		71	73	2
CLAYEY GRAVEL		73	75	2

DCNR/DWR Received JUN 22 1995 LAS VEGAS OFFICE

Date started 5-3, 1995
Date completed 5-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	75 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	75

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-15'/15-35' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 35 feet to 75 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Address 4670 SO POLARIS AVE (Contractor)
LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed (By driller performing actual drilling on site or contractor)
Date 6-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627