



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 47771
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14023

1. OWNER BULLFROG MINE ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 519 BEATTY, NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 22 T 12 N/S R 46 E Nye County
PERMIT NO. MO-931 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, GRAVEL + ROCKS		0	150	150
COARSE SAND + GRAVEL		150	360	210
CLAY GRAVEL w/ CLAY STRINGERS		360	670	310
CLAY GRAVEL		680	800	120

8. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)
From 11 Inches To 0 Feet 800 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.62</u>	<u>5.4</u>	<u>4.32</u>	<u>+1</u>	<u>800</u>
		<u>(SCH 80 PVC)</u>		

Perforations:
Type perforation PVC SCREEN SCH 80
Size perforation .020
From 760 feet to 780 feet
From _____ feet to _____ feet

RECEIVED
JUN 16 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 100 feet to 800 feet

Date started 5-30, 1995
Date completed 6-6, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level 660 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER WELL SERVICES Contractor
Address 6475 GARY AVE Contractor
LAS VEGAS, NV. 89139

Nevada contractor's license number 022311
issued by the State Contractor's Board

Nevada driller's license number issued by the 1594
Division of Water Resources, the on-site driller:

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 6-14-95