PZ-94-15

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 477 4773/4774
Permit No.
Basin 061

NOTICE OF INTENT NO. 28564

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ SE ¼ Sec. 19 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. M/O-441 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DISPLACED 16 LB/GAL CEMENT SLURRY				
FROM 1,160 FT TO SURFACE IN THE DEEP				
COMPLETION, AND FROM 440 FT TO SURFACE				
IN THE SHALLOW COMPLETION				

Date started MARCH 30, 1996
Date completed MARCH 31, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,170 Feet Depth Cased 1,160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches	0 Feet	46 Feet
6-1/2 Inches	46 Feet	1,170 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	23.5	.375	0	46
1-1/4	2.25	SCH 40	0	340
2	5	.218	0	1,100

Perforations:
Type perforation SLOT
Size perforation 1/8"
From 1-1/4 340 feet to 440 feet
From 2 1,100 feet to 1,160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 320, 1,070 feet to 440, 1,170 feet

9. WATER LEVEL
Static water level (1-1/4" 328')(2" 311') feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1948

Signed DARYL GLANZMAN (By driller performing actual drilling on site or contractor)
Date APRIL 5, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627