WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47780
Permit No. 57537
Basin 212

NOTICE OF INTENT NO. 16018

1. OWNER Phillip J. Piazza
MAILING ADDRESS 1870 Bird Av
San Jose, CA 95125

ADDRESS AT WELL LOCATION Fore Views & Log Cabin

2. LOCATION SW ¼ NE ¼ Sec. 5 T. 19 N/S R 60 E Clark County

PERMIT NO. 57537 (Issued by Water Resources) | Parcel No. 016-0800-65 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel Boulder		0	60	
Hard Black Rock		60	75	
Sand Gravel Boulder		75	120	
Yellow Clay		120	140	
Brown Clay	5-10	140	210	
Sand Gravel Boulder	60	210	280	

RECEIVED
JUN 08 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-26, 1995
Date completed 6-2, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		188	0	270

Perforations:
Type perforation Torch
Size perforation 1/8 in
From 210 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55 feet
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 270 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling (Contractor)
Address 8170 S Haven (Contractor)
Las Vegas, NV 89123

Nevada contractor's license number issued by the State Contractor's Board 38155

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798

Signed Marvell E. Redding Jr.
By driller performing actual drilling on site or contractor

Date 6-6-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627