

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 47787  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14989

1. OWNER BARRICK GOLDSTRICK ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE  
MAILING ADDRESS P.O. BOX 29  
ELKO, NEVADA 89801  
2. LOCATION NE 1/4 NW 1/4 Sec 30 T 36 N 50 E EUREKA County  
PERMIT NO. 441 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DISPLACED 16 LB/GAL CEMENT SLURRY		FROM 500		
FT TO SURFACE IN DEEP COMPLETION				
DISPLACED 16 LB/GAL CEMENT SLURRY		FROM 360		
FT TO SURFACE IN SHALLOW COMPLETION				

8. WELL CONSTRUCTION  
Depth Drilled 500 Feet Depth Cased 500 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 25  
12 1/4 Inches 25 Feet  
6 1/2 Inches 500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>7</u>	<u>23.5</u>	<u>.375</u>	<u>0</u>	<u>25</u>
<u>1 1/2</u>	<u>2.25</u>	<u>SCH 40</u>	<u>0</u>	<u>500</u>
<u>1 1/2</u>	<u>2.25</u>	<u>SCH 40</u>	<u>0</u>	<u>380</u>

Perforations:  
Type perforation SLOT  
Size perforation .025  
From 240 feet to 380 feet  
From 460 feet to 500 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 220, 438 feet to 374, 500 feet

9. WATER LEVEL  
Static water level 17 feet below land surface  
Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature 81 °F Quality GOOD, CLEAR

Date started OCTOBER 31, 19 94  
Date completed OCTOBER 31, 19 94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LANG EXPLORATORY DRILLING Contractor  
Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UTAH 84104  
Nevada contractor's license number issued by the State Contractor's Board 0021976  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410  
Signed JOHN VIERGUTZ  
By driller performing actual drilling on site or contractor  
Date John Viergutz