BX-4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47815
Permit No.
Basin 062

NOTICE OF INTENT NO. 25581

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NW ¼ Sec. 36 T 38 (N)S R 48 E EUREKA County
PERMIT NO. WAIVER M/O-723A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	140	140
BLACK & GRAY ROCK	260'	140	980	840
BLACK ROCK		980	1,220	240
BLACK ROCK, SOME CLAY		1,220	1,660	440
BLACK ROCK		1,660	1,780	120
BLACK ROCK, SOME CLAY		1,780	2,100	320

Date started 11-15, 1994
Date completed 12-2, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2,100 Feet Depth Cased 2,080 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	40 Feet
7 7/8 Inches		40 Feet	2,100 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22	.250	0	40
1 ¼	3	SCHED 80	0	320
2	5	.218	0	2,020

Perforations:
Type perforation 1¼" DRILLED 2" SLOT
Size perforation 1/8" 1/8"
From 1¼" 320 feet to 380 feet
From 2" 2,020 feet to 2,080 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 300', 2,000' feet to 400', 2,100' feet

9. WATER LEVEL
Static water level 337 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 51 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1808
Signed SCOTT ACKLEY Scott Ackley (By driller performing actual drilling on site or contractor)
Date 12/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627