WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47834
Permit No.
Basin 040

NOTICE OF INTENT NO. 30871

1. OWNER Barton's Club 93
MAILING ADDRESS P.O. Box 523
Jackpot, NV 89825

ADDRESS AT WELL LOCATION
180 ft. N of original well (behind club)

2. LOCATION NW ¼ SW ¼ Sec. 1 T. 47 N/S R. 64 E. ELko County
PERMIT NO. 24284/24285 Relocate
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel fill		0	3	3
Topsoil		3	11	8
White sandy clay		11	18	7
Brown sandy clay & gravel		18	26	8
Brown clay		26	178	152
Sand, gravel & clay		178	213	35
Black sand & gravel		213	220	7
Soft brown sandstone	x	220	285	65
Gray decomposed sandstone	x	285	360	75
Brown sandstone	x	360	378	18
Soft gray basalt	x	378	417	39
Reddish brown rhyolite	x	417	430	13
Gray basalt		430	453	23
Fractured gray basalt	z	453	500	47

'95 FEB 16 A10:46
STATE ENGINEER'S OFFICE

Date started February 7, 19 95
Date completed February 10, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	500 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	22.36#	.250	+1	500

Perforations:
Type perforation Factory
Size perforation 1/8 x 3"
From 280 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 58 ft.
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 181 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elsing Drilling & Pump Co., INc.
Contractor
Address P.O. Box 919
Contractor
Twin Falls, ID 83303-0919

Nevada contractor's license number issued by the State Contractor's Board 0017177

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1741

Signed Mark Sibert
By driller performing actual drilling on site or contractor

Date February 14, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627