WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42848
Permit No.
Basin

NOTICE OF INTENT NO. 14654

1. OWNER James Sutton
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3451 W. Ramona

2. LOCATION NW ¼ NE ¼ Sec. 24 T. 20 S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-773-13 (Parcel No.) Charlestown Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	10	5
Calichie		10	14	4
Clay		14	21	7
Calichie		21	23	2
Clay		23	32	9
Calichie		32	35	3
Clay		35	46	11
Calichie		46	48	2
Clay		48	54	6
Calichie	WB	54	57	3
Clay		57	68	11
Calichie	WB	68	71	3
Clay		71	79	8
Calichie	WB	79	81	2
Clay		81	93	12
Calichie	WB	93	95	2
Clay		95	113	18
Calichie	WB	113	119	6
Clay		119	134	15
Calichie	WB	134	140	6

Date started May 16, 19 95
Date completed May 19, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JUN 13 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 5/24/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627