WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

in book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47853
Permit No.
Basin 163

NOTICE OF INTENT NO. 14648

1. OWNER Ellenburg Development
MAILING ADDRESS
ADDRESS AT WELL LOCATION Tuskegee & Emerald.

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 24S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay.		0	7	7
Gravel & Clay		7	70	63
Gravel & Calichie.		70	85	15
Calichie.		82	85	3
Sand & Clay.		85	90	5
Cemented Gravel & Clay.		90	110	20
Clay.		110	120	10
Limestone.		120	126	6.
Clay.		126.	128.	2.
Calichie		128.	132.	4.
Gravel & Clay.	WB.	132.	158.	16.
Calichie.	WB.	158.	163	5
Gravel.	WB.	163	180	17

Date started 5-10, 1995
Date completed 5-12, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JUN 13 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	180.

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.57	.188.	-1	180.

Perforations:
Type perforation SAW.
Size perforation ⅛ inch by 3 inch.
From 160 feet to 180. feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180. feet

9. WATER LEVEL
Static water level 96 ft. feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30580.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed ..... By driller performing actual drilling on site or contractor
Date 5-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627