

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16154

1. OWNER Kerr ADDRESS AT WELL LOCATION 3480 Unicorn Ave
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NE 1/4 Sec 35 T 20S N/S R 53 E Nye County
 PERMIT NO. 42-702-23 Calvada Valley Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Caliche		7	11	4
Clay		11	23	12
Caliche		23	26	3
Clay		26	36	10
Caliche		36	40	4
Clay		40	52	12
Caliche	WB	52	57	5
Clay		57	69	12
Caliche	WB	69	71	2
Clay		71	83	12
Caliche	WB	83	86	3
Clay		86	95	9
Caliche	WB	95	99	4
Clay		99	118	19
Caliche	WB	118	122	4
Clay		122	135	13
Caliche	WB	135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 140 Feet
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 8" x 1 3/4"
 From _____ feet to _____ feet
 From 0 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

Date started May 25 1995
 Date completed May 30 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			



9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan By driller performing actual drilling on site or contractor
 Date 6/27/95