WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47864
Permit No.
Basin

NOTICE OF INTENT NO. 16204

1. OWNER Robert Evanston
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1980 Vickie Ann

2. LOCATION NE ¼ NE ¼ Sec. 2 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-122-17 (Parcel No.) Game bird (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	12	8
Calichie		12	14	2
Clay		14	24	10
Calichie		24	30	6
Clay		30	36	6
Calichie		36	38	2
Clay		38	54	16
Calichie	WB	54	57	3
Clay		57	65	8
Calichie	WB	65	70	5
Clay		70	79	9
Calichie	WB	79	84	5
Clay		84	92	8
Calichie	WB	92	97	5
Clay		97	103	6
Calichie	WB	103	105	2
Clay		105	119	14
Calichie	WB	119	124	5
Clay		124	136	12
Calichie	WB	136	140	4

Date started June 30, 19 95
Date completed July 5, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR Received JUL 25 1995 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 7/13/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627