




WHITE—DIVISION OF WATER RESOURCES  
 PRIMARY—CLIENT'S COPY  
 INK—WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 47866  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16199

1. OWNER Alan Crumb ADDRESS AT WELL LOCATION 1420 E. Heritage Dr.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 11 T. 21S R. 53 E. Mye County  
 PERMIT NO. 44-391-11 Parcel No. \_\_\_\_\_ Subdivision Name Red Rock Estates

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	12	12
Caliche		12	15	3
Clay		15	60	45
Caliche	WB	60	63	3
Clay		63	88	25
Caliche	WB	88	90	2
Clay		90	118	28
Caliche	WB	118	120	2
Clay		120	137	17
Caliche	WB	137	140	3

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2 1/4 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 5" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet


9. WATER LEVEL  
 Static water level 56 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started June 26 1995  
 Date completed June 29 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)



10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D  
 By driller performing actual drilling on site or contractor  
 Date 7-6-95

