



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 47870
Permit No. _____
Basin 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14344

1. OWNER Rusty Lisk ADDRESS AT WELL LOCATION _____
MAILING ADDRESS HCR 73 Box 22501 _____
Pahrump, NV. 89041 _____
2. LOCATION NW 1/4 NW 1/4 Sec 9 T. 20S N/S R. 53 E _____
35-163-07 _____
PERMIT NO. _____
Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Caliche		0	3	3
Clay		3	45	42
Caliche		45	48	3
Clay		48	66	18
Caliche	WB	66	68	3
Clay		68	85	17
Caliche	WB	85	88	3
Clay		88	97	9
Caliche	WB	97	100	3
Clay		100	115	15
Caliche	WB	115	117	2
Clay		117	131	14
Caliche	WB	131	134	3
Clay		134	140	6

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 140 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.99</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation Factory Saw cut
Size perforation 2 7/8" x 3 1/4"
From _____ feet to _____ feet
From 100 feet to 130 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 _____
 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

Date started 7/4 1995
Date completed 7/16 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
Received
JUL 25 1995
LAS VEGAS OFFICE

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
Nevada contractor's license number 30880 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1042
Signed Thomas Dan 7/16/95
Date _____