WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47872
Permit No.
Basin 162

NOTICE OF INTENT NO. 16183

1. OWNER Anthony Redling
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3820 W. Blosser

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 19S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-234-11 (Parcel No.) Bell Vista (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Calichie		0	3	3
Clay		3	55	52
Calichie	WB	55	58	3
Clay		58	73	15
Calichie	WB	73	75	2
Clay		75	95	20
Calichie	WB	95	97	2
Clay		97	115	18
Calichie	WB	115	118	3
Clay		118	132	14
Calichie	WB	132	135	3
Clay		135	152	17
Calichie	WB	152	155	3
Clay		155	177	22
Calichie	WB	177	180	3
Clay		180	192	12
Calichie	WB	192	194	2
Clay		194	218	24
Calichie	WB	218	220	2
Clay		220	232	12
Calichie	WB	232	235	3
Clay		235	248	13
Calichie	WB	248	250	2

Date started June 14, 19 95
Date completed June 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR Received JUL 25 1995 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From Feet	To Feet
	12¼	0	250

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	250

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 210 feet to 230 feet
From 120 feet to 140 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 7/13/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627