

47881
Log No. _____
Permit No. _____
Basin _____
NOTICE OF INTENT NO. 22807

photo wch
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER PERRY SMITH ADDRESS AT WELL LOCATION 21590 DELTA DRIVE
MAILING ADDRESS 155 MOGUL MT VIRGINIA CITY, NV
reno nv 89523

2. LOCATION NW 1/4 NE 1/4 Sec 32 T 18 N R 21 E STOREY County
PERMIT NO. 03-051-07 VIRGINIA CITY HIGHLANDS Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MULTI COLORED VOL SANDS		0	2	
GREEN WHITE PURPLE GREY VOL ROCK (HARD)		2	8	
PURPLE CLAY WITH PURPLE WHITE VOL ROCK		8	25	
PURPLE WHITE & GREEN VOL ROCK HARD		25	130	
LIGHT GREEN PURPLE WHITE VOL ROCK WITH TRACES OF LIGHT GREEN & PURPLE CLAY		130	142	
LIGHT GREEN & WHITE VOL ROCK WITH GREY CLAY		142	170	
LIGHT GREEN & PURPLE VOL ROCK		170	280	
280 TD	X			

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cascd 280 Feet

HOLE DIAMETER (BIT SIZE)
From 10 5/8 inches 0 Feet 55 Feet
To 8 1/2 inches 55 Feet 28 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1296	.188	+1 1/2	280

Perforations:
Type perforation FACTORY SAWED
Size perforation 3/32 X 3"
From 260 feet to 240 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 53 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 280 feet to 53 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. PUMP & WELL SERVICE INC Contractor
Address 1800 1/2 FRAZER AVENUE Contractor
SPARKS, NV 89431
Nevada contractor's license number 0035387-A issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5-11-95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>	<u>5</u>	<u>3 1/2</u>

Date started 5-8 19 95
Date completed 5-10 19 95