

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24691

1. OWNER RON GOTT ADDRESS AT WELL LOCATION 3475
MAILING ADDRESS 3475 Farm District Rd. FARM DISTRICT RD
FERNLEY NV. 89408 FERNLEY NV. 89408
2. LOCATION SW 1/4 SE 1/4 Sec. 22 T 20 N 3 R 23 E LYON County
PERMIT NO. 21-472-10 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SAND, GRAVEL + COBBLE STONE</u>		<u>0</u>	<u>54</u>	<u>54</u>
<u>COURSE SAND + CLAY BROWN</u>		<u>54</u>	<u>97</u>	<u>43</u>
<u>COURSE SAND + GRAVEL</u>	<u>X</u>	<u>97</u>	<u>154</u>	<u>57</u>

195 MAY 16 AM 5:2
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 154 Feet Depth Cased 154 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 154 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/8</u>		<u>.188</u>	<u>0</u>	<u>154</u>

Perforations:
Type perforation M, 11
Size perforation 1/8" + 3"
From 134 feet to 154 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 100 feet to 154 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow Good G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

Date started 4-11, 1995
Date completed 4-20, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>18</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling & Det. Contractor
Address P.O. Box 668 Contractor
Silver Springs, NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed H.L. Smith
By driller performing actual drilling on site or contractor
Date 4-25-1995



STATE OF
MISSISSIPPI