Permits 68313-5, 70762-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK ILIADA

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47886
Permit No.
Basin C84 ~~084~~ ~~085~~

NOTICE OF INTENT NO. 14835

1. OWNER Carl D + Laurinna Harold
MAILING ADDRESS 1230 River Berry Dr
Reno Nev 89509

ADDRESS AT WELL LOCATION 076-320-3
ON GRASS VALLEY ROAD

2. LOCATION ~~S~~ E ¼ ~~N~~ NE ¼ Sec ~~23~~ 14 T ~~23~~ N/S R 20 E E Washoe County
PERMIT NO. ~~005 312~~ Issued by Water Resources | 076-320-03 Parcel No. | T 23 N | Palomino Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	30	
Sand		30	45	
Clay		45	80	
Clay with streaks of sand		80	120	
Clay & Vol Rock		120	206	

Deepened by log # 82188

N39.866219
W119.695509 NAD27

'95 MAY 16 A10:51
RECEIVED
STATE ENGINEERS OFFICE

Date started March 28, 1995
Date completed April 19, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	90	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 206 Feet Depth Cased 206 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	50 Feet
8 11 Inches	50 Feet	206 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8			0	155
			165	186

Perforations:
Type perforation Factory
Size perforation
From 155 feet to 165 feet
From feet to feet
From 186 feet to 206 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature 56 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller
Contractor
Address P.O. 92
Contractor
Smith, NV
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786
Signed Ray Higginbotham
By driller performing actual drilling on site or contractor
Date April 19 - 95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627