


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 47891
 Permit No. _____
 Basin. _____



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19630
DUTCH FLAT ROAD

1. OWNER Phillip Geertson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NW 1/4 NE 1/4 Sec. 22 T. 38 N/S R. 39 E County _____

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY SOIL		0	18	18
GRAVEL & SAND		18	43	25
FINE GRAVEL SAND	✓	43	67	24
SANDY CLAY		67	75	8
CLAY W SAND & GRAV.		75	140	65
FINE SAND & SMALL GRAV.	✓	140	165	25
SANDY CLAY		165	187	22
HARD PAN SAND & GRAV.		187	205	18
SANDY CLAY		205	210	5
SAND & GRAVEL	✓	210	218	8
SANDY CLAY		218	258	40
SAND & GRAVEL	✓	255	262	7

8. WELL CONSTRUCTION
 Depth Drilled 262 Feet Depth Cased 258 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10" Inches 0 Feet 68 Feet
6" Inches 73 Feet 258 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>.250</u>	<u>73</u>	<u>258</u>

Perforations:
 Type perforation K PACKER 5 FT HEAD PIPE
 Size perforation 5 FT JOHNSONS 20 SHOT SURGONS
 From 258 feet to 262 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 68 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 31 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Phillip Geertson (owner)
 Address 16615 Barrows Rd
Adrian Or 97901
 Nevada contractor's license number issued by the State Contractor's Board N/A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1980
 Signed Wance Ray Dayton
 By driller performing actual drilling of site or contractor
 Date 5-11-95

Date started 2-29 1995
 Date completed 5-3 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>		<u>8</u>