WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47906
Permit No.
Basin 049

NOTICE OF INTENT NO. 29173

1. OWNER Robert Kilburn
MAILING ADDRESS P.O. Box 3013
Elko, NV 89803

ADDRESS AT WELL LOCATION N. side of 24th St. between Osage Ave & Crow Ave.

2. LOCATION NW ¼ SE ¼ Sec. 19 T. 35 N/S R. 56 E. Elko County

PERMIT NO. (Issued by Water Resources) | Parcel No. 36-018-06 | Subdivision Name MVR #4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Clay		3	12	9
Brown Siltstone		12	180	168
Brown Siltstone with pea gravel	X	180	230	50
Brown Clay		230	265	35
Brown Siltstone with some gravel		265	290	25

Date started 3-9, 1995
Date completed 3-20, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80+		4

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	290 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1 1/2	290

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 270 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 290 feet

9. WATER LEVEL
Static water level 120' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Daniel Hersel (By driller performing actual drilling on site or contractor)
Date 3-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627