

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29283

1. OWNER PAUL WATKINS ADDRESS AT WELL LOCATION UNIT I
 MAILING ADDRESS 505 240 ROAD
PALM SPRING VALLEY
 2. LOCATION 22 1/4 SW 1/4 Sec 35 T. 23N N/S RANGE 20E County _____
 PERMIT NO. 005306 Parcel No. 76-110-0155 (new) Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Water Bearing SAND</u>		<u>145</u>	<u>160</u>	
<u>Dep 4</u>		<u>160</u>	<u>202</u>	
<u>CORSS SAND</u>		<u>202</u>	<u>232</u>	
<u>Deepening of log # 17269</u>				
<u>D&A see log # 85947</u>				

8. WELL CONSTRUCTION
 Depth Drilled 232 Feet Depth Cased 232 Feet

HOLE DIAMETER (BIT SIZE)
6" From _____ To 232 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>188</u>	<u>0</u>	<u>142</u>
			<u>162</u>	<u>202</u>
			<u>222</u>	<u>232</u>

Perforations:
 Type perforation FACTORY
 Size perforation 6"
 From _____ feet to _____ feet
 From 142 feet to 162 feet
 From _____ feet to _____ feet
 From 202 feet to 222 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started Feb 27-1995
 Date completed MARCH 7-1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>25 ft</u>	<u>2 HRS</u>

9. WATER LEVEL
 Static water level 103 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature 56 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address Box 92
SMITH, NV 89441 Contractor
 Nevada contractor's license number 32166
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 786
 Division of Water Resources, the on-site driller
 Signed Roy Nicamburn
 By driller performing actual drilling on site or contractor
 Date 3-7-95