

OFFICE USE ONLY  
 Log No. 47909  
 Permit No. \_\_\_\_\_  
 Basin 049 I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29108

1. OWNER Valley View RV Park ADDRESS AT WELL LOCATION 1 mile east of Elko  
 MAILING ADDRESS P.O. Box 6130  
Elko, NV 89803  
 2. LOCATION SE 1/4 SW 1/4 Sec. 30 T. 35 N. R. 56 E. Elko County  
 PERMIT NO. M/O 897 ) 06-320-20-4 Tract of Land  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                            | Water Strata | From | To  | Thickness |
|-------------------------------------|--------------|------|-----|-----------|
| Top Soil                            |              | 0    | 3   | 3         |
| Silty sand                          |              | 3    | 15  | 12        |
| Sand & Med. Gravel                  | X            | 15   | 21  | 6         |
| Sandy Clay                          |              | 21   | 70  | 49        |
| Sand & Med Gravel                   | X            | 70   | 90  | 20        |
| Coarse Gravel                       | X            | 90   | 100 | 10        |
| Gravel packed with 8-12 silica sand |              |      |     |           |
| Bentonite 50-65'                    |              |      |     |           |
| Steel monument cemented at surface  |              |      |     |           |

95 MAR 30 1995  
STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
6 1/2 Inches \_\_\_\_\_ Feet 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>2 3/8</u>       |                     | <u>Sch 80 PVC</u>       | <u>+3</u>   | <u>100</u> |

 Perforations:  
 Type perforation PVC Screen  
 Size perforation \_\_\_\_\_ 020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 75 feet to 95 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 70 feet to 100 feet  
 9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-10, 1995  
 Date completed 3-11, 1995

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>12</u> |                               | <u>1.5</u>   |
|  |           |                               |              |
|  |           |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hackworth Drilling, Inc. Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-24-95