

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29913

1. OWNER SONNIE Milano ADDRESS AT WELL LOCATION 222 BAR NONE LANE
MAILING ADDRESS 193-2 pleasant valley lot 4 pleasant valley ESTATES

2. LOCATION SW 1/4 NW 1/4 Sec. 26 T. 32 N/S R. S7 E ELKO County
PERMIT NO. 23-014-04 Parcel No. pleasant valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sub soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Cemented SANDSTONE</u>		<u>2</u>	<u>85</u>	<u>83</u>
<u>Rock</u>		<u>85</u>	<u>93</u>	<u>8</u>
<u>Clay</u>		<u>93</u>	<u>113</u>	<u>20</u>
<u>Rock</u>		<u>113</u>	<u>123</u>	<u>10</u>
<u>Clay</u>		<u>123</u>	<u>137</u>	<u>14</u>
<u>Cemented SANDSTONE</u> X		<u>137</u>	<u>158</u>	<u>11</u>
<u>Rock</u> X		<u>158</u>	<u>170</u>	<u>12</u>

8. WELL CONSTRUCTION

Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>170</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>170</u>

Perforations:
Type perforation slots
Size perforation 3/4 x 3"

From 150 feet to 170 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 170 feet

9. WATER LEVEL

Static water level 96 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
Address PO. Box 525 ELKO 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shovel C. Fertig
By driller performing actual drilling on site or contractor
Date 3-20-85

Date started 3-6, 1985
Date completed 3-10, 1985

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>22</u>		<u>3.5</u>