

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28906**

1. OWNER **RONALD WILHITE** ADDRESS AT WELL LOCATION **1456 WILLOW CREEK**
 MAILING ADDRESS **GARDNERVILLE** **GARDNERVILLE**

2. LOCATION **SW 1/4 SW 1/4 Sec 35 T. 13 N R. 20 E DOUGLAS** County
 PERMIT NO. _____ Parcel No. **23-540-14** Subdivision Name **WILLOW CREEK**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand some gravel		0	10	10
cemented gravel		10	21	11
Sandy clay w/ gravel		21	38	17
Sandy clay		38	51	13
Sandy clay w/ gravel		51	63	12
gravel w/ sandy clay		63	103	40
gravel w/ sandy clay streaks	✓	103	142	
Sandy clay w/ gravel		142	157	15
large gravel w/ sandy clay	✓	157	178	21
sandy clay w/ gravel		178	180	2

8. WELL CONSTRUCTION
 Depth Drilled **180** Feet Depth Cased **180** Feet

HOLE DIAMETER (BIT SIZE)

From	To
10.58 Inches	0 Feet 100 Feet
9.75 Inches	100 Feet 150 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.75	13	.188	±2	180

Perforations:
 Type perforation **Factory Slotted / T.C.**
 Size perforation **3.2 7/32**
 From **160** feet to **180** feet
 From **T.C. 130** feet to **140** feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal **100**

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From **100** feet to **180** feet

9. WATER LEVEL
 Static water level **45** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cold** °F Quality **Good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **EDDCO EXPLORATION, INC** Contractor
 Address **7780 CURRY RD** Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board **27673**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1535**
 Signed **Jerrell W. Phinell**
 By driller performing actual drilling on site or contractor
 Date **3-21-95**

Date started **3-17, 1995**
 Date completed **3-21, 1995**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	25+		3