WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47920
Permit No.
Basin 105

NOTICE OF INTENT NO. 28908

1. OWNER LEHMAN + SONS BUILDERS
MAILING ADDRESS P.O. BOX 1073
GARDNERVILLE, NV

ADDRESS AT WELL LOCATION 2185 CALLE HERMOSA
FISH SPRINGS, NV

2. LOCATION NE ¼ SE ¼ Sec. 31 T. 13 (N)S R. 21 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-180-30 (Parcel No.) FISH SPRINGS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay w/ cobbles		0	21	21
Sandy clay		21	27	6
Cobbles, gravel w/ sandy clay		27	39	12
Sandy clay		39	44	5
gravel, cobbles		44	56	12
Sandy clay		56	62	6
gravel, cobbles		62	68	6
Sandy clay		68	75	7
gravel		75	90	15
Sandy clay		90	102	12
gravel		102	105	3
Sandy clay		105	120	15
gravel, sand	—	120	127	7
Sandy clay		127	135	8
Course sand w/ some sandy clay	—	135	150	15
Sandy clay		150	170	20
Course sand w/ small gravel	—	170	178	8
Sand		178	185	7
Sandy clay		185	190	5

Date started 3-7, 1995
Date completed 3-15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	10	—	2

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	160 Feet
5 3/4 Inches		160 Feet	190 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1.5	160
5	10	.188	155	190

Perforations:
Type perforation Factory Slotted / T.C.
Size perforation
From T.C. 120 feet to 140 feet
From Fact. 140 feet to 160 feet
From 5" Fact. 160 feet to 180 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 99 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-16-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627