

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26533

1. OWNER FRISILIANO ARIPE ADDRESS AT WELL LOCATION None  
 MAILING ADDRESS Unk

2. LOCATION NW 1/4 NE 1/4 Sec. 7 T. 34 N. S. R. 56 E Elko County  
 PERMIT NO. LOT 7 BIKJ Parcel No. # Last Chance Ranch Unit #3 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clay, silt, loose rock</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>Humboldt Lm</u>		<u>7</u>	<u>75</u>	<u>68</u>
<u>Elko Lm. Gray shale</u>		<u>68</u>	<u>220</u>	<u>152</u>
<u>Sandy clay</u>	<u>1 ppm</u>	<u>220</u>	<u>230</u>	<u>10</u>
<u>Shale</u>		<u>230</u>	<u>258</u>	<u>28</u>
<u>Sandy shale</u>		<u>258</u>	<u>295</u>	<u>37</u>
<u>Shale</u>		<u>295</u>	<u>300</u>	<u>5</u>
	<u>T.D</u>	<u>300</u>		

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
<u>10</u>	<u>0</u>	<u>7.5</u>	<u>7.5</u>
<u>8</u>	<u>7.5</u>	<u>300</u>	<u>300</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+4</u>	<u>301</u>

Perforations:  
 Type perforation Teach cut  
 Size perforation \_\_\_\_\_  
 From 220 feet to 240 feet  
 From 255 feet to 290 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 142 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MUTH DRILLING Co Contractor  
 Address 203 PINE ST. Contractor  
ELKO, NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
 Signed James V. Muth  
 By driller performing actual drilling on site or contractor  
 Date 3-30-95

Date started 3-22, 1995  
 Date completed 3-29, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>20</u>	<u>1 hr</u>