

Log No. **47928**  
 Permit No. \_\_\_\_\_  
 Basin **105**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **29309**  
 ADDRESS AT WELL LOCATION **1489 Sanchez Rd Gardnerville NV 89410**

1. OWNER **Jerry Blades Construction**  
 MAILING ADDRESS **East Valley Rd Gardnerville NV 89410**  
 2. LOCATION **NE 1/4 SE 1/4 Sec 26 T 13 R 20 E Douglas County**  
 PERMIT NO. **23-540-20**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUC**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard pack clays and gravels		0	18	18
Brown Clay		18	45	27
Course Sands and Clay		45	93	48
Solid Gummy Brown Clay Zone (Smooth)		93	156	63
Broken Gravels w/ small clays		156	180	24
Rusty Rock				

8. WELL CONSTRUCTION  
 Depth Drilled **180** Feet Depth Cased **180** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **10 3/4** Inches To **0** Feet  
 To **180** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13.03</b>	<b>4/88</b>	<b>0</b>	<b>180</b>

Perforations:  
 Type perforation **Mill Slot**  
 Size perforation **3 x 3/32**  
 From **100** feet to **180** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal **105**  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From **105** feet to **180'** feet

9. WATER LEVEL  
 Static water level **7.5'** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **20** P.S.I.  
 Water temperature **Cold** °F Quality **Good**

Date started **3-29** 19**95**  
 Date completed **4-2** 19**95**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<b>20</b>	<b>2.5</b>	<b>3 HRS</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **AH Pump Company** Contractor  
 Address **3351 Hwy 50 E #3 Carson City NV 89701** Contractor  
 Nevada contractor's license number issued by the State Contractor's Board **31839**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**  
 Signed **Michael Haak**  
 By driller performing actual drilling on site or contractor  
 Date **4-2-95**