

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26534

1. OWNER Shiela Sayko ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 945 Spring Valley Parkway
Elko, NV 89801
 2. LOCATION NE 1/4 NE 1/4 Sec. 5 T. 35 S. R. 57 E. Elko County
 PERMIT NO. 26-009-01-9 Parcel No. 444 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	1	1
Sand, gravel, cobbles		1	7	6
Sandy clay		7	170	163
Gravel	<u>Spn</u>	170	172	2
Sandy clay		172	189	17
Sand	<u>vvv</u>	189	202	13
Sandy clay		202	210	8
		T.D.	210	

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 212 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 55 Feet
8 Inches 55 Feet 210 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>210</u>

Perforations:
 Type perforation Touch cut
 Size perforation 1/2 x 4
 From _____ feet to _____ feet
 From 160 feet to 180 feet
 From 190 feet to 215 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to T.D. feet

9. WATER LEVEL
 Static water level 154 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started 4-6 1995
 Date completed 4-4 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>5</u>	<u>2.0</u>
	<u>40</u>	<u>15</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING CO. Contractor
 Address 203 PINE ST. Contractor
ELKO, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/6/95