




WHITE-DIVISION OF WATER RESOURCES  
 PRIMARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 47962  
 Permit No. \_\_\_\_\_  
 Basin 163



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14682

1. OWNER PEGGY ELLEN BURG ADDRESS AT WELL LOCATION DOLOMITE TUSKEGEE + SANDY VALLEY NV.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 NW 1/4 Sec. 22 T 24 N/S R 56 E CLARK County  
 PERMIT NO. 580-160-122 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material           | Water Strata | From | To  | Thick-ness |
|--------------------|--------------|------|-----|------------|
| SANDY LOAM         |              | 0    | 9   | 9          |
| CLAY               |              | 9    | 35  | 26         |
| CMT. SAND + GRAVEL |              | 35   | 40  | 5          |
| CLAY + GRAVEL      |              | 40   | 75  | 35         |
| CMT. SAND + GRAVEL |              | 75   | 85  | 10         |
| CALICHE            |              | 85   | 90  | 5          |
| CMT. SAND + GRAVEL |              | 90   | 120 | 30         |
| CALICHE            | W.B          | 120  | 130 | 10         |
| CLAY + GRAVEL      |              | 130  | 145 | 15         |
| CALICHE            | W.B          | 145  | 150 | 5          |
| CLAY               |              | 150  | 160 | 10         |

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 160 Feet  
12 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8 5/8</u>       | <u>16.94</u>        | <u>.188</u>             | <u>0</u>    | <u>160</u> |

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1/2 INCH BY 3/4 INCH  
 From 160 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 160 feet to 50 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO. Contractor  
 Address P.O. Box 3505 Pahrump NV. Contractor  
89041  
 Nevada contractor's license number 410020 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Samie Brown  
 By driller performing actual drilling on site or contractor  
 Date 7-24-95

Date started 7-19, 1995  
 Date completed 7-21, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |

