



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT


Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 47970

Permit No. _____

Basin. _____



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 17011

1. OWNER Miles Henson ADDRESS AT WELL LOCATION Lot 8 Mustang
MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec. 7 T. 17S N/S R. 52 E Nye County
PERMIT NO. 21-171-09 Parcel No. _____ Subdivision Name Forty Bar Est

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/Dirt-Cobbles		0	12	12
Cemented Gravel				
Clay		12	34	22
Cemented Conglo- merate Rock		34	51	17
Clay		51	54	3
Caliche	WB	54	56	2
Clay		56	60	4
Caliche	WB	60	74	14
Clay		74	82	8
Limestone	WB	82	91	9
Clay		91	120	29
Gravel Sand	WB	120	140	20


8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.75</u>	<u>16.99</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8" x 3"
From _____ feet to _____ feet
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 140 feet



Date started July 10 1995
Date completed July 11 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80388 Contractor
Pahrump, NV.
Nevada contractor's license number 30880
issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 8/18/95