WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47977
Permit No.
Basin

NOTICE OF INTENT NO. 17019

1. OWNER Ideked
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 1 Sunland

2. LOCATION SW ¼ NE ¼ Sec. 8 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-113-06 (Parcel No.) Sunland Est. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	13	7
Calichie		13	17	4
Clay		17	24	7
Calichie		24	26	2
Clay		26	33	7
Calichie		33	36	3
Clay		36	43	7
Calichie		43	45	2
Clay		45	54	9
Calichie	WB	54	57	3
Clay		57	63	7
Calichie	WB	63	66	3
Clay		66	78	16
Calichie	WB	78	80	2
Clay		80	96	16
Calichie	WB	96	102	6
Clay		102	113	11
Calichie	WB	113	116	3
Clay		116	121	5
Calichie	WB	121	124	3
Clay		124	135	11
Calichie	WB	135	140	5

Received AUG 14 1995 LAS VEGAS OFFICE

Date started 7-17, 1995
Date completed 7-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 8/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627