WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47974
Permit No. 76326
Basin

NOTICE OF INTENT NO. 16206

1. OWNER Frank Danesi
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5101 Oakridge

2. LOCATION NW ¼ NE ¼ Sec. 12 T. 21S N/S R. 53 E. Nye County
PERMIT NO. 76326 (Issued by Water Resources) 44-251-41 (Parcel No.) 44-521-41 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE COMMERCIAL
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	16	12
Calichie		16	19	3
Clay		19	27	8
Calichie		27	30	3
Clay		30	35	5
Calichie		35	38	3
Clay		38	53	15
Calichie	WB	53	57	4
Clay		57	68	11
Calichie	WB	68	73	5
Clay		73	87	14
Calichie	WB	87	89	2
Clay		89	98	9
Calichie	WB	98	102	4
Clay		102	114	12
Calichie	WB	114	119	5
Clay		119	127	8
Calichie	WB	127	129	2
Clay		129	136	7
Calichie	WB	136	140	4

DCNR/DWR Received AUG 14 1995 LAS VEGAS OFFICE

Date started July 5, 1995
Date completed July 7, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3/4"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 8/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627