WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47984
Permit No.
Basin
NOTICE OF INTENT NO. 17035

1. OWNER Jack Schultz
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4311 E Santivito

2. LOCATION SE ¼ SW ¼ Sec 17 T 21S N/S R 54 E Nye County
PERMIT NO. Issued by Water Resources | 45-171-17 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	18	12
Calichie		18	23	5
Clay		23	29	6
Calichie		29	37	8
Clay		37	53	16
Calichie		53	56	3
Clay		56	61	5
Calichie	WB	61	66	5
Clay		66	70	4
Calichie	WB	70	74	4
Clay		74	82	8
Calichie	WB	82	85	3
Clay		85	97	12
Calichie	WB	97	101	4
Clay		101	113	12
Calichie	WB	113	115	2
Clay		115	126	11
Calichie	WB	126	129	3
Clay		129	137	8
Calichie	WB	137	140	3

DCNR/DWR Received AUG 14 1995 LAS VEGAS OFFICE

Date started July 28, 19 95
Date completed July 31, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80 358 Contractor
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 8/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627