



WHITE-DIVISION OF WATER RESOURCES
 PRIMARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 47990
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 14368

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Rich & Linda Riccah ADDRESS AT WELL LOCATION 3641 Nevada Ave
 MAILING ADDRESS HCR # 65 Box 72563 Pahrump NV. 89041
 2. LOCATION NW 1/4 NW 1/4 Sec. 20 T. 21S N/S R. 53 County NYE
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blown Clay		0	8	8
DCC. Caliche		8	26	18
Blown Clay	X	26	75	49
Grey Clay	X	75	95	20
Hard Caliche	X	95	97	2
Grey Clay	X	97	128	31
Hard Caliche	X	128	132	4
Grey Clay	X	132	140	8

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12" Inches To 0 Feet
140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory
 Size perforation 1/2 x 4/8
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 5.0'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 80 feet to 140 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 8-5-95
 Date completed 8-9-95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>		<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry's Water Well Service
 Address PO Box 3392 Pahrump NV.
 Nevada contractor's license number issued by the State Contractor's Board 0035801
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1216
 Signed Larry H Jenkins
 By driller performing actual drilling on site or contractor
 Date 8-9-95

