



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY


STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Permit No. 47992

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.140



1. OWNER MERLE B. STEELE ADDRESS AT WELL LOCATION COUGAR + LINDEL
MAILING ADDRESS _____
2. LOCATION NW 1/4 SE 1/4 Sec 13 T 22 N/S R 60 E CLARK County
PERMIT NO. 176-13-701-005 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ROCKS + CLAY</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SMT. GRAVEL</u>		<u>10</u>	<u>100</u>	<u>90</u>
<u>SANDSTONE</u>		<u>100</u>	<u>200</u>	<u>100</u>
<u>RED SANDSTONE</u>	<u>310</u>	<u>200</u>	<u>350</u>	<u>150</u>
<u>RED SANDSTONE</u>		<u>350</u>	<u>500</u>	<u>150</u>
<u>W/STREAKS CLAY</u>				

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 500
12 1/4 Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>500</u>

Perforations:
Type perforation FACTORY JAW
Size perforation 1 1/2 x 2 1/2
From 440 feet to 480 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 60 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 60 feet to 500 feet



Date started 8-3 1995
Date completed 8-10 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
Static water level 290 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the reports true to the best of my knowledge.
Name DESERT DRILLING Contractor
Address 6475 GARY AVE Contractor
LAS VEGAS, NV. 89137
Nevada contractor's license number 34274
issued by the State Contractor's Board:
Nevada driller's license number issued by the 1966
Division of Water Resources, the on-site driller:
Signed Jymall Coull
By driller performing actual drilling on site or contractor
Date 8-15-95