



WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 48001  
Permit No. 212  
Basin. 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14388

1. OWNER NDEP ADDRESS AT WELL LOCATION Intersection of Palm St / Wyoming Ave  
MAILING ADDRESS 555 E. Washington Ave #4300 Las Vegas 89101 Las Vegas  
2. LOCATION E 1/2 1 T 21 W/S R 61 E CLARK County  
PERMIT NO. MD-2613 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
<u>Fill - Asphalt / base</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>CLAYEY SAND</u>		<u>1</u>	<u>2</u>	<u>1</u>
<u>CLAYEY SILT</u>		<u>2</u>	<u>4</u>	<u>2</u>
<u>SILTY CLAY</u>		<u>4</u>	<u>11</u>	<u>7</u>
<u>CLAYEY SILT w/ sand</u>	<u>Y</u>	<u>11</u>	<u>19.5</u>	<u>8.5</u>

8. WELL CONSTRUCTION  
Depth Drilled 19.5 Feet Depth Cased 19.5 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 19.5  
6 Inches 0 Feet 19.5 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>19.5</u>

Perforations:  
Type perforation slotted screen  
Size perforation 0.10 inch  
From 7 feet to 19.5 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 6  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 6 feet to 19.5 feet

9. WATER LEVEL  
Static water level 7.46 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Tim Aten c/o WTI  
Address 3611 W. Tompkins Ave  
Las Vegas 89103  
Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 8/1/95

Date started 7/27, 1995  
Date completed 7/27, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

