



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 48008
Basin No. 5

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17007

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER Phuramp Dairy

ADDRESS AT WELL LOCATION
Lot 4 St well 4

2. LOCATION NW 1/4 SE 1/4 Sec 9 T 20S N/S R 53 E NYE County

PERMIT NO. Mo 2589 35-111-14 Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well
 Replace
 Abandon
 Deepen

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Monitor
 Irrigation
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	3	3
caliche		3	6	3
clay		6	8	2
caliche		8	11	3
clay		11	16	4
caliche		16	19	3
clay		19	24	5
caliche		24	26	2
clay		26	35	9
caliche		35	38	3
clay		38	43	5
caliche	TR	43	46	3
clay		46	51	5
caliche	WS	51	55	4
clay		55	61	6

8. WELL CONSTRUCTION
Depth Drilled 61 Feet Depth Cased 61 Feet

HOLE DIAMETER (BIT SIZE)

From 9 7/8 Inches To 6 1 Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>			<u>Sch 40</u>	<u>0</u>
				<u>61</u>

Perforations:
Type perforation Slotted
Size perforation 1 1/2 V2
From 31 feet to 56 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 21 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 24 feet to 61 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling
Contractor

Address Hee 78 Box 80358
Phuramp NV 89041
Contractor

Nevada contractor's license number 30880
issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1642

Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 8/22/95

Date started 8-16 19 95
Date completed 8-19 19 95

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift
G.P.M. (Feet Below Static) Time (Hours)

