WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48004
Permit No.
Basin
NOTICE OF INTENT NO. 12048

1. OWNER Alton Jenkins
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3051 W. Shelly

2. LOCATION NE ¼ NE ¼ Sec. 24 T. 20 S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-772-02 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	10	5
Calichie		10	13	3
Clay		13	24	11
Calichie		24	26	2
Clay		26	39	13
Calichie		39	42	3
Clay		42	53	11
Calichie	WB	53	56	3
Clay		56	69	13
Calichie	WB	69	72	3
Clay		72	84	12
Calichie	WB	84	87	3
Clay		87	98	11
Calichie	WB	98	103	5
Clay		103	112	9
Calichie	WB	112	114	2
Clay		114	128	14
Calichie	WB	128	131	3
Clay		131	140	11

DCNR/DWR Received AUG 25 1995 LAS VEGAS OFFICE

Date started August 14, 1995
Date completed August 17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 18 x 1 3/4
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HC 78 Box 8358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 8-23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627