



WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48021
Permit No. _____
Basin. 162

NOTICE OF INTENT NO. 16079

1. OWNER J.L. Investments ADDRESS AT WELL LOCATION _____
MAILING ADDRESS _____ 3751 S. Mallard Ave.
2. LOCATION SE 1/4 SE 1/4 Sec. 36 T 20-S N/S R 53 E Nye County _____
PERMIT NO. 41-134-08 Calvada Valley Unit: 2 Blk: 33
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Sandy loam		4	10	6
Brown clay		10	36	26
Brown clay & caliche		36	46	10
Brown clay		46	67	21
Limestone		67	71	4
Brown clay & caliche	X	71	104	33
Brown clay		104	122	18
Brown clay & caliche	X	122	154	32
Brown clay		154	160	6

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet
HOLE DIAMETER-(BIT SIZE)
From To
12 Inches 0 Feet 160 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
Type perforation Torch Cut
Size perforation 1/2" width 8" long
From 120 feet to 160 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Pike Well Drilling, LLC Contractor
Address P.O. Box 56 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed [Signature]
By driller performing actual drilling on site or contractor
Date August 3, 1995

Date started July 31, 1995
Date completed July 31, 1995

7. WELL TEST DATA

X TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

