WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE COPY
Log No. 48028
Permit No.
Basin 190

NOTICE OF INTENT NO. 26954

1. OWNER Deeter Trust
MAILING ADDRESS 774 Mays Blvd
Incline Village, NV 89451

ADDRESS AT WELL LOCATION 1820 Hwy 50
S L Tahoe, NV

2. LOCATION SE ¼ NW ¼ Sec. 15 T 14 N/S R 18 E Douglas County
PERMIT NO. NE SW (Issued by Water Resources) 01-110-11 (Parcel No.) None (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Forest Loam		0	2	2
Sandy DG		2	20	18
DG w Large Blders		20	42	22
DG Mixed w A Tan-Brwn Clay		42	83	41
V Hard DG or DG Blders	X	83	163	80
Broken or Fractured Altered Granodiorite	X	163	230	67
V Solid		230	261	31
Fractured or Broken	X	261	305	44
Well is case Thusly:				
167' of Blank 8", w 2' of Stickup				
40' of Wirewrap Screen 0.080				
In the 8" Hole is 10' of Blank up in the 8" screen, 20' Perf 20' of Blank 20' Perf 20' Blank 20' Perf, 5' of Blank w cap on end				

Date started 9/12, 1994
Date completed 9/20, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50±		6 Hrs

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 Inches	0 Feet	205 Feet
8 Inches	205 Feet	305 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		1/4	+2	165

Perforations:
Type perforation Screen & Slots
Size perforation 3x 3/32 .080 screen
From 165 feet to 205 feet
From 220 feet to 280 feet
From 280 feet to 280 feet
From 280 feet to 300 feet
From 300 feet to 305 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 205 feet

9. WATER LEVEL
Static water level ? feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisek (By driller performing actual drilling on site or contractor)
Date 10/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627