

Log No. 48030  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16162

1. OWNER Gary Hunter ADDRESS AT WELL LOCATION 1910 E Kellogg  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec 14 T. 21 S. N/S R. 53 E Nye County  
 PERMIT NO. 44-621-14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	5
Caliche		3	5	2
Clay		5	14	9
Caliche		14	22	8
Clay		22	33	10
Caliche		33	39	6
Clay		39	54	15
Caliche	WB	54	58	4
Clay		58	73	15
Caliche	WB	73	75	2
Clay		75	81	6
Caliche	WB	81	84	3
Clay		84	92	8
Caliche	WB	92	95	3
Clay		95	102	7
Caliche	WB	102	104	2
Clay		104	113	9
Caliche	WB	113	116	3
Clay		116	124	8
Caliche	WB	124	127	3
Clay		127	139	12
Caliche	WB	139	142	3
Clay		142	145	3
Caliche	WB	145	148	3

8. WELL CONSTRUCTION  
 Depth Drilled 148 Feet Depth Cased 148 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 1 1/8 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>148</u>

Perforations:  
 Type perforation Factory Saw cut  
 Size perforation 1/8" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 108 feet to 128 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 148 feet

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 7/31/95

Date started May 30 1995  
 Date completed 6/3 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

