WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48032
Permit No.
Basin

NOTICE OF INTENT NO. 17028

1. OWNER Milton Schroeder
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1141 Horn St.

2. LOCATION SE ¼ NE ¼ Sec. 17 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 36-302-05 (Parcel No.) Cal Vegas Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	16	12
Calichie		16	18	2
Clay		18	27	9
Calichie		27	29	2
Clay		29	38	9
Calichie		38	41	3
Clay		41	53	12
Calichie	WB	53	57	4
Clay		57	69	12
Calichie	WB	69	78	9
Clay		78	90	12
Calichie	WB	90	93	3
Clay		93	100	7
Calichie	WB	100	104	4
Clay		104	113	9
Calichie	WB	113	119	6
Clay		119	128	9
Calichie	WB	128	131	3
Clay		131	137	6
Calichie	WB	137	140	3

DCNR/DWR Received AUG 14 1995 LAS VEGAS OFFICE

Date started July 21, 19 95
Date completed July 23, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV.
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 8/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627