WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48041
Permit No.
Basin 162

NOTICE OF INTENT NO. 16190

1. OWNER Louise Parker
MAILING ADDRESS
ADDRESS AT WELL LOCATION 701 W. Kimberly

2. LOCATION NE ¼ SW ¼ Sec. 16 T. 19S N/S R. 53 E/W Nye County
PERMIT NO. (Issued by Water Resources) 29-254-22 (Parcel No.) Country Place II (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	7	3
Clay		7	17	10
Calichie		17	19	2
Clay		19	27	8
Calichie		27	30	3
Clay		30	37	7
Calichie		37	42	5
Clay		42	49	7
Calichie		49	53	4
Clay		53	69	16
Calichie		69	72	3
Clay		72	79	7
Calichie	WB	79	83	4
Clay		83	92	9
Calichie	WB	92	94	2
Clay		94	103	9
Gravel-Sand	WB	103	117	14
Clay		117	129	12
Calichie	WB	129	132	3
Clay		132	144	12
~~Calichie~~	~~WB~~			
Gravel-Sand	WB	144	161	17
Clay		161	169	8
Calichie	WB	169	173	4
Clay		173	175	2

Received AUG 14 1995 LAS VEGAS OFFICE

Date started June 19, 1995
Date completed June 21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	Feet	0 Feet	175 Feet
Inches	Feet		Feet
Inches	Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From ~~100~~ 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dim
(By driller performing actual drilling on site or contractor)
Date 7/25/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627