



WHITE--DIVISION OF WATER RESOURCES
 CANARY--CLIENT'S COPY
 PINK--WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 18050
 Permit No. I
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17030

1. OWNER Michael Hildebrand ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 11 T. 21S N/S R. 53 E _____ County
 PERMIT NO. 44-301-18 Parcel No. _____ Subdivision Name Joycelyn Est.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	2	2
Caliche		2	4	2
Clay		4	11	7
Caliche		11	13	2
Clay		13	20	7
Caliche		20	24	4
Clay		24	39	15
Caliche		39	42	3
Clay		42	54	12
Caliche	WB	54	57	3
Clay		57	69	12
Caliche	WB	69	82	13
Clay		82	83	1
Caliche	WB	83	87	4
Clay		87	99	12
Caliche	WB	99	102	3
Clay		102	113	11
Caliche	WB	113	115	2
Clay		115	126	11
Caliche	WB	126	129	3
Clay		129	134	5
Caliche	WB	134	137	3

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 7/8	16.94	.188	0	140

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1/8" x 3/8"
 From _____ feet to _____ feet
 From 100 feet to 102 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. 54 WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Tahump, NV 89091
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller.
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 7/31/95

Date started July 21, 1995
 Date completed July 24, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

