

Log No. **48052**  
 Permit No. \_\_\_\_\_  
 Basin. **102**  
 NOTICE OF INTENT NO. **26037**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Cathy & Jim Wetlock Purchasers** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **American Property Services 5590 Elm St**  
**1317 Jones St Reno, NV 89503** \_\_\_\_\_  
 2. LOCATION **NW 1/4 SE 1/4 Sec 1 T. 17 N/S R. 24 E. 10** County \_\_\_\_\_  
 PERMIT NO. **NA** Issued by Water Resources Parcel No. **117-074-16** Subdivision Name **Mountain View Sub 2**

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **Mod**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Clay		8	12	4
Sand & Gravel		12	61	49
Gravel		101	110	9
Clay	135	110	135	25
Gravel Strata	138	135	138	3
Clay	148	138	148	10
Coarse Sand	152	148	152	4

8. WELL CONSTRUCTION  
 Depth Drilled **152** Feet Depth Cased **153** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **12 1/4** Inches To **152** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13</b>	<b>1.88</b>	<b>1</b>	<b>152</b>

Perforations:  
 Type perforation **Tool Cut**  
 Size perforation **3/16 x 6" x 4000 perf**  
 From **128** feet to **138** feet  
 From **142** feet to **152** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From **50** feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **38** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **C** °F Quality **Good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Pease Drilling Inc** Contractor  
 Address **P.O. 599** Contractor  
**55, N. 89429**  
 Nevada contractor's license number issued by the State Contractor's Board **0031841**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1876**  
 Signed **Donna Pease**  
 By driller performing actual drilling on site or contractor  
 Date **4/10/95**

Date started **4/4/95**, 19\_\_\_\_\_  
 Date completed **4/16/95**, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>35-40</b>	<b>2</b>	<b>2 3/4 hrs</b>