

Log No. **48065**
 Permit No. **179**
 Basin. **1**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24653

1. OWNER Cary Brunson ADDRESS AT WELL LOCATION 6 miles north of Ely
 MAILING ADDRESS P.O. Box 775
Ely, NV 89301

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 17 N8 R 63 E White Pine County
 PERMIT NO. 50-A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Gravel		5	10	5
Clay & Gravel		10	20	10
Gravel		20	65	45
Clay & Gravel		65	110	45
Clay		110	115	5
Water Bearing Gravel	x	115	120	5
Clay & Gravel		120	140	20
Water Bearing Gravel	x	140	145	5
Clay & Gravel		145	155	10
Water Bearing Gravel	x	155	175	20
Clay		175	183	8

'95 MAY -3 A1138
 JERRY VILLO
 STATE ENGINEERS DRILLING

8. WELL CONSTRUCTION
 Depth Drilled 183 Feet Depth Cased 183 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet 183 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	0	183

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 8 rows
 From 61 feet to 183 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 183 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor

Address 557 Ely Avenue
 Contractor
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jarrod D. Christiansen
 By driller performing actual drilling on site or contractor
 Date April 27, 1995

Date started October 6, 19 94
 Date completed October 10, 19 94

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300	105	1