

48068

Log No. _____
 Permit No. 79
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24656

1. OWNER Jeff Brunson ADDRESS AT WELL LOCATION 6 miles North of Ely, Nevada
 MAILING ADDRESS 4705 South 4000 West Delta, Utah 84624

2. LOCATION SW 1/4 SW 1/4 Sec. 15 T. 17 N/S R. 63 E. White Pine County
 PERMIT NO. 79 Parcel No. _____ Subdivision Name Cross Timbers
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	7	7
Gravel		7	15	8
Clay & Gravel		15	20	5
Gravel		20	40	20
Clay & Gravel		40	65	25
Gravel		65	75	10
Clay & Gravel		75	95	20
Water Bearing Sand & Gravel	X	95	105	10
Clay & Gravel		105	115	10
Water Bearing Sand & Gravel	X	115	120	5
Clay & Gravel		120	125	5
Water Bearing Sand & Gravel	X	125	150	25
Clay		150	169	19

8. WELL CONSTRUCTION
 Depth Drilled 169 Feet Depth Cased 169 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 169 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	0	169

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 Rows
 From 65 feet to 169 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 169 feet

9. WATER LEVEL
 Static water level 97 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 95 November 17, 1994
 Date completed 95 November 21, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	150	63	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerrold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date April 27, 1995

95 MAY -3 AM 138
 RECEIVED
 STATE ENGINEERS OFFICE